

AFTER YOUR LEAD SERVICE LINE IS REPLACED

RESTORATION OF YOUR PROPERTY

PVWC's Contractor Pacific Construction will restore your lawn, driveway and sidewalk back to its original condition. The restoration will be completed within 45 days after the service line is replaced.

If you have questions about service line replacement or restoration at your property, please contact Pacific Construction at 1-844-PVWCLEAD or leadservice@pacifcon.com

Temporary
Asphalt Repair



Permanent
Sidewalk Repair




If sidewalk restoration is needed, the area will be temporarily secured. After a short settlement period, a new sidewalk slab will be constructed.

Temporary Backfilled
Top Soil



Final Seeding
of Lawn




If lawn restoration is needed, top soil and seeding will be replaced. During the winter months seeding will take place when the weather warms up.

FLUSHING YOUR PLUMBING AFTER SERVICE LINE REPLACEMENT

After your lead service line has been replaced, it is important to flush all of the pipes in your house. Flushing will remove any lead that may have entered the pipes in your house during construction. Flush all interior plumbing before using your water. **DO NOT USE** hot water until the initial flushing is completed to prevent lead particles from settling in your hot water tank.

Whole Building Flushing Instructions

1. Find all the faucets that will drain, including the basement and on all floors in your house.
2. Remove aerators and screens whenever possible, including the shower heads, from all faucets you plan to flush. Include the laundry tubs, hose-bibs, bathtubs, and showers as flushing points.
3. Open the faucets in the basement or lowest floor in the house. Leave all faucets running at highest rate possible, using cold water.
4. Open the faucets on next highest floor of the house. Continue until faucets are open on all floors.
5. After all faucets are opened, leave the water running for at least 30 minutes.
6. After 30 minutes, turn off the first faucet you opened and continue to turn off other faucets in the same order you turned them on.
7. Clean aerators/screens at each faucet. You may need to replace screens/aerators if too old or worn. Conduct a 30 minute flush every other week for three months.



This report contains information about your drinking water. If you do not understand it, please have someone translate it for you.


Este informe contiene información sobre su agua potable. Si no lo entiende, pídale a alguien que lo traduzca.

આ અહેવાલ મને તમારી પાણીની ગુણવત્તા વિશે જાણવા માટે આપવામાં આવેલ છે. જો તમે અર્થઘટિત કરી શકતા નથી તો કૃપા કરીને કોઈકને આ અહેવાલ અનુવાદ કરવા માટે આપને આજ્ઞા કરવામાં આવે છે.

يحتوي هذا التقرير على معلومات مهمة عن مياه الشرب التي تشربها. إذا لم تفهم هذه المعلومات الرجاء الاستعانة بأحد ليرجمها لك.

Cleaning Your Aerator

1. Remove faucet aerators and clean out any particles. The aerator is usually at the tip of the faucet and can be screwed off to clean.
2. After your lead service line is replaced, clean debris from aerators and screens once a month for six months. After six months, clean debris twice a year.



Daily Flushing

Daily flushing should continue for six months after your lead service line has been replaced. Flush water through the plumbing in your house for 5 minutes each morning (or after an extended period of no water usage) before drinking. NOTE: Taking a shower, running the dishwasher or flushing a toilet will flush your lines.



To learn more about PVWC's lead service line replacement program, call or visit:

973-340-4300 leadfree@pvwc.com

www.pvwcleadserviceline.com



@thePVWC



@passaic_valley_water



@PVWC